



QSK (CXRS) - Conceptual Design Review OP2 (Ladungsaustauschspektroskopie am Neutralheizstrahl)


CDR 06.02.2020

O. P. Ford¹, M. Steffen¹, C. Biedermann¹, M. Hirsch¹.

1: Max-Planck Institut für Plasmaphysik, Greifswald/Garching, Germany



Component Overview



Changes for OP2+

Upgrade for OP2 consists of 4 distinct changes:

1) Add cooling to existing AEA21 components (K1):

- Thermal straps on shutter.


2) Add cooling to existing AEM21 components (K2):

- Water-cooled panel.
- Thermal straps on shutter + water circuit.

3) Addition of 2nd immersion tube to AEA21 to view NI20.

4) Rebuild of AET20/21 tubes (K3) due to redesign of HST.


AEA21



2 immersion tubes:


AEA21-O: Upper immersion tube from OP1.2b.
AEA21-U: Copy of AEA21-O - discussed later.

- Cooled front plate provides protection of port wall and most diagnostics parts [QMR2]
- QSK Shutter only open during NBI operation ~20seconds.
- Shutter contains aluminium (RSA905) mirror and should remain $< 300^{\circ}\text{C}$.





AEA21 - Vacuum window

- Vacuum window only exposed during **20s** open period.
- 100kW/m^2 at plasma boundary --> **20W** on window.
- **30°C / min** heating rate = 5°C in 10 seconds, but well above **2°C / min** specification of window.
- Add 'sacrificial window' (glass plate) in front of vacuum window to absorb most of power (XUV-VUV)
- Cycle time of NBI ~ 10 min - enough time to cool by radiation or conduction to surrounding metal.





AEA21 - Shutter - Copper thermal straps

When closed, back side of shutter exposed to full 100kW m^{-2} x 30min.
Shutter holds RSA905 aluminium mirror --> requires cooling.




AEA21 - Concept

Copper straps to be shielded from plasma exposure, also reducing radiation load to moving components.



Open shutter:





AEA21 - Cover

Ray traced 100kW m⁻² at plasma boundary to cover:

Cover: 1.6 kW

Shutter etc. : 200W (all parts cooled by straps)

FEM thermal calculation of cover gives max 550°C, if copper plated under top of cover.





Only 3mm Stainless steel --> 1200°C

With 3mm copper layer on
inside of top cover --> 550°C

AEA21 - Strap protection plates

Heat loads to protection plate $\sim 200\text{W}$

Thermal calculation for steady state gives $\sim 300^\circ\text{C}$ max







AEA21 - Thermal strap

Worst case temperature of mirror calculated assuming all 200W heating of shutter/mirror block.

Conductance of strap $\sim 111/L$ W/K.
Mirror max T = 300°C



- 1) With 2 straps and cover, 18GJ is OK by x2
- 2) 1GJ is OK even with no cover and only 1 strap

9 / 42 Thermocouple will be installed in shutter to monitor temperature rise in OP2.1 --> confirm safety.




QSK AEA21 Cooling - Planning

Funding: 7k€ of 20k€ requested from contingency for QSK hardening.

Time plan:

- Expected DDR ready around April
- AEA21 handover to AS ready around Dec 2020 - giving ~ 4 months buffer as A21 is last flange to be closed.





Changes for OP2+

Upgrade for OP2 consists of 4 distinct changes:

- 1) Add cooling to existing AEA21 components (K1):
 - Thermal straps on shutter.

- 2) **Add cooling to existing AEM21 components (K2):**
 - **Water-cooled panel.**
 - **Thermal straps on shutter + water circuit.**

- 3) Addition of 2nd immersion tube to AEA21 to view NI20.

- 4) Rebuild of AET20/21 tubes (K3) due to redesign of HST.



AEM21

Immersion tube in AEM21.

- Views NBI beam from above.
- No room for port-liner with existing immersion tube.
- Vessel/port wall otherwise exposed to heat load.

Proposed solution:



- Water cooled front-plate covering most of port.
- Small cut-out to allow necessary diagnostic view.



View including neighbouring AEN21 Portliner,

AEM21



Include back surface 'port shield' to protect port wall, 'zwickel' and welding seams. Together with AEN21 port-liner and it's gap protection fins (Spaltshutz/Rohrkragen), blocks most of heat load to vessel/port walls.



AEM21




- Front plate mounted on two bolts and metal bracket:
- Bolts and bracket to be installed before re-installation of surrounding panels (~Feb 21)
- Discussion with AS-Tech:
 - Need to provide bolts and brackets.
 - Some panel mount pieces available from AS.
 - Need to precisely define positioning.

Head-on view (looking up at port from inside vessel):




AEM21

- Space for water cooling pipes limited.
- Contact of immersion tube with pipes in LC2 (Ausheizen) --> stress on pipes join to panel.
- Solution: Pipes on side of tube with narrowest as-built gap. Tube moves away in other load cases.



AEM21

- Installation procedure complicated by length of pipes:
a \ll b: Pipes too long to be installed inside.






TODO: Measure some length (b) in as-built port to set length of pipes so they can be installed unloaded.

AEM21 - Welding water lines at passring

Welding of pipes to passring:


- Use 'Orbitalschweißzangen' to weld inside and outside.



Weld from inside (as AEM41 - PL)



AEM21: Shutter cooling

- Cooling of shutter using 2 straps as for AEA21. Heat load to closed shutter is the same (~200W)
- Connect to copper block with dedicated cooling line.
- Protection plates to avoid exposure of copper straps to plasma.



AEM21: Window exposure

- Window exposure also similar to AEA21 ~ 10 - 20W --> **30 K / min >> 2 K / min** specified.
- Install sacrificial window
- Protection collar sub-optimal in OP1.2b (Stahlblech)
 - > Redesign with sacrificial window holder and attached water cooling pipes (which run to shutter cooling block)



AEM21: Heat load - Vessel/Ports


Preliminary thermal evaluation.

Ray tracing 100 kW m⁻² from plasma surface to simplified model of all components: [radExposure-all30x30x30]

AEM21 port wall: 50 W [radExposure-portWalls (50x50x??)]

Zwickel: 25 W


= 75W to vessel walls



AEM21: Heat load - Front plate


Ray tracing 100 kW m^{-2} from plasma surface to simplified model of all components: [radExposure-all30x30x30]
Total 5 kW heat load ($\sim 60 \text{ kW m}^{-2}$)
Calculation: 2mm copper, no radiation exchange.

Current design:



Max: 870°C

With cooling line along base:





Max: 250°C

--> Use thicker copper layer and/or reroute pipe

AEM21: Heat load - Port shield

Port Shield. 470W, 2mm Steel, No Copper
Conduction to pipe and front plate, no radiation exchange.



Too hot - would lead to significant radiation exchange to port wall.

1) Use much thicker steel ($\geq 5\text{mm}$) or copper plating --> Consider fast current collapse forces.

2) Route water pipe through centre of shield area --> Consider stiffness vs flexibility during installation.

AEM21: Heat load - Shutter

Preliminary thermal evaluation.

Ray tracing 100 kW m⁻² from plasma surface to simplified model of all components: [radExposure-all30x30x30]

AEM21 port wall: 50 W [radExposure-portWalls (50x50x??)]

Zwickel: 25 W

= 75W to vessel walls

Front plate: 5000 W

Port Shield: 470W

= 5100W to ACK60-PL via front-plate water circuit.

Immersion tube: 0.1W

Protection collar: 50W

Shutter: 40W

Shutter strap cover : 150W


Straps direct: 2W

= **200W via straps**

= 250W to ACK60-DIA via immersion tube water circuit.


Non-cooled steel components: 80W

Worst case M3, radiation equilibrium = 400°C




AEM21: Heat load - Shutter

Shutter: 40W
Shutter strap cover : 150W
Straps direct: 2W
= 200W via straps



- Head load, strap length and material are all the same as AEA21
--> Same temperature development of shutter and aluminium mirror.



- 1) With 2 straps and cover, 18GJ is OK by x2
- 2) 1GJ is OK even with no cover and only 1 strap


Thermocouple will be installed in shutter to monitor temperature rise in OP2.1 --> confirm safety.



QSK AEM21 Cooling - Planning

Funding: 11k€ of 20k€ requested from contingency for QSK hardening.

Time plan:





Changes for OP2+

Upgrade for OP2 consists of 4 distinct changes:

- 1) Add cooling to existing AEA21 components (K1):
 - Thermal straps on shutter.


- 2) Add cooling to existing AEM21 components (K2):
 - Water-cooled panel.
 - Thermal straps on shutter + water circuit.

- 3) Addition of 2nd immersion tube to AEA21 to view NI20.**

- 4) Rebuild of AET20/21 tubes (K3) due to redesign of HST.

CXRS Immersion tube AEA21 -U

- Copy AEA21 immersion tube for lower-left of AEA21 flange, for observation of NI20.
- Originally reserved for CXRS on NBI (no CN required?).



CXRS Immersion tube AEA21 -U

- All vacuum-interface components identical to AEA21-O.
- Resubmit specification and contract to Trinos (Pfeifer Vacuum).
Includes vacuum tests (+Restgasanalyse)

Additional resources:

- 1x extra Shutter (Shutter-Schieber Steuerung)
Common SPS --> No special CoDAC integration required.
- ~10k€ for tube and parts.
- Some TD manufacturing.
- Vacuum test of assembled shutter drive (DN40 CF) - (As chit #18 of OP1.2b DRB)

- No DE requirement.
- No EN requirement.
- No CoDAC requirement.

CXRS Immersion tube AEA21-U

Optics:

Plan is to use this toroidal view for QRI/QSV, replacing AEQ21 toroidal port that was used in OP1.2, but now needs a pinhole.

Add fibres or advanced CXRS measurements inside QSV/QRI soft iron box.

Details still need to be agreed with QRI/QSV, will be presented later.

- Present at DDR?


Projects:

QSV/P042 - Fast Video - R.O.: Marco Krause (E4)

QRI/P143 - Coherence Imaging - R.O. Dorothea Gradic (E4)

For info only:


Objective lens on end of fibre bundle (as used in AE21Q OP1.2b), fibre bundle to repositioned QSV/QRI soft iron box.




AEA21-U - Optics

Preliminary ray-tracing shows basic optical concept works for QSV/QRI.

- Single 17mm F/1 objective gives required FOV.



Single DO-1795






QSK AEA21-U - Planning

Funding:

9k€ from existing QSK funds.

5k€ of 20k€ requested from contingency for QSK hardening.

Time plan:





Changes for OP2+

Upgrade for OP2 consists of 4 distinct changes:

- 1) Add cooling to existing AEA21 components (K1):
 - Thermal straps on shutter.


- 2) Add cooling to existing AEM21 components (K2):
 - Water-cooled panel.
 - Thermal straps on shutter + water circuit.

- 3) Addition of 2nd immersion tube to AEA21 to view NI20.

- 4) Rebuild of AET20/21 tubes (K3) due to redesign of HST.**

AET20/21 - Redesign of HST

- QSK had optics in one window of AET20/21 immersion tubes of QYB/P008 (Heat Shield Thermography) during OP1.2.
- Immersions tube require complete redesign for OP2.
- Combined system under development (pre-CDR) for QYB/QSK.
 - Design not CDR ready - **not discussed here!**



- Design maintains performance of QSK from AET20/21.
- Immersion tubes, vacuum components, safety etc, all part of QYB --> P008 CDR, DDR
- Air-side optics remain as in OP1.2b.
- Resulting changes to QSK air-side mechanics will be presented in QSK DDR.



Changes for OP2+

Upgrade for OP2 consists of 4 distinct changes:

- 1) Add cooling to existing AEA21 components (K1):
 - Thermal straps on shutter.

- 2) Add cooling to existing AEM21 components (K2):
 - Water-cooled panel.
 - Thermal straps on shutter + water circuit.

- 3) Addition of 2nd immersion tube to AEA21 to view NI20.

- 4) Rebuild of AET20/21 tubes (K3) due to redesign of HST.

- 5) Consideration of passive CXRS (AEK41) for OP2**




Passive CXRS - AEK41

'Passive CXRS' system on AEK41 will remain as in OP1.2, but we need to consider heating of window:

650x350mm * 100kW m⁻² = 23kW into port.
22kW on 6cm window at 2m distance = **2W**
On port area (720x400mm) = 200W



AEK41 Portliner = 650x350mm (inside)



Passive CXRS - AEK41 - Window heating

22kW on 6cm window at 2m distance = **2W**

Power = 2W

Diameter = 60mm

Thickness ~ 6mm

Material = Fused Silica


Density = 2.2 g cm^{-3}

Mass = 37g

Specific heat capacity = $740 \text{ J kg}^{-1} \text{ K}^{-1}$

Heating rate = **4 K / min**

Max heating rate = **25 K / min** (manufacturer specification).



--> Assumes volumetric heating of glass, but 2W is low enough to not pose a significant risk.

Power to flange = 200W.

Material = Steel

Flange size = 740 x 560 x 38mm

Density = 8 g cm^{-3}

Mass = 120kg

Specific heat capacity = $420 \text{ J kg}^{-1} \text{ K}^{-1}$

Heating rate = **0.2 K / min**

+ Air side of flange is convectively cooled

--> Flange will stay effectively room temperature.

Documentation

- 1-QSK-S0002.1: Projektspezifikation - *~ready*
- 1-QSK-T0003.1: Safety analysis - *~ready, update with cooling calculations at DDR*
- 1-QSK-P1000: WBS - up to date
- CNs:
 - 1-QSK-C0008: AEM21 PL --> Frontplate, *~ready*
 - AEK41 Change of QSC to QSK
 - Addition of AEA21-U - *Is CN Required?*
 - 1-Q-C0010: Addition of Shutter AEA21-U
- QAAPs:
 - Reassembly AEA21 - *Copy 1-QSK-Q0001*
 - Installation/calibration AEA21 - *Copy 1-EGG21-Q2418*
 - Calibration for AEA21-U - *After planning with QSV/QRI. Integrate in 1-EGG31-Q2418 copy for OP2.0*
 - Installation AEM21 Frontplate - **New. To be made with AS.**
 - Installation AEM21 Tube - *Copy 1-EGG21-Q2283 with modification for presence of front plate.*
 - Calibration AEM21, AET2x - *Copy 1-EGG21-Q2383.*
- Sonderfreigaben: AEA21-U mirror: *Repeat 1-QSK-Q0009*
 AEA21-U objective: *After design of A21-U optics.*
- CAT - To be developed for OP2.0 start up.
- Interfaces: As OP1.2,
 - + QMR for cooling via AEA21 front plate.
 - + ACK60 for water cooling of AEM21 PL + DIA.
 - + QSV/QRI for sharing of new immersion tube AEA21-U.
- Media: Water cooling from ACK60

Resource requirement

E3:

- Design and assembly of all components.
- 20k€ for cooling (from risk budget, K1/K2)
- 15k€ for AEA21-U (K7).
- 2k€ for parts in AET2x (K3)
- Hot leak test AEM21 Immersion tube

Outside E3, very low-resource demand:

TD:

- Multiple small parts for cooling components and extra components for K7 and K3.
~ 100s hours.

AS:

- More complex installation of front plate than PL ~ 4 days.
- Laying of cables/lines to 1 extra shutter.
- Installation AEM21 immersion tube ~ 4 hours.

EN:

- Thermal calculations AEA21 (K1) front plate (assigned to QMR, in progress)
- Thermal calculations AEM21 ~ 3 weeks.

CoDAC:

- Connection of 1 extra shutter to Shutter/Schieber Steuerung.
- Nothing required for control, data acquisition or data processing.

DE:

- Routing of cables/lines to 1 extra shutter.
- Routing ACK60 'last 1m' for diagnostik + front plate on AEM21.



Summary

- 1) Add cooling to existing AEA21 components (K1):
 - EN calculations (by QMR - now)
 - Purchase and test straps
 - DDR



- 2) Add cooling to existing AEM21 components (K2):
 - Water-cooled panel: Calculations (EN?), DDR, Find supplier
 - Thermal straps on shutter + water circuit.

- 3) Addition of 2nd immersion tube to AEA21 to view NI20.
 - Ready to order immersion tube, the rest progresses with #1
 - Optics integration with QSV/QRI (next week) --> present at QSK DDR.

- 4) Rebuild of AET20/21 tubes (K3) due to redesign of HST.
 - Vacuum hardware at QYB CDR
 - Optics integration at QSK DDR.



- 5) AEK41
 - No changes. Accepted?, otherwise calculations by EN.

AEM41 - Why not spiral pipes?






AEM41 - Pipe welding



Kontrollskizze für Montage Tauchrohr CXRS



- Bemerkungen:**
- Fertigung der CF-Flansch bezogenen Merkmale (Schneidkantenometrie, Lochkreise sowie Rauheiten, Mass- und Lagetoleranzen) nach Z-Nr. 1-pvh03ah005--p-fz-1 für CF-Blindflansche DN300.
 - Seite S1: unverschnittene konzentrische Flanscheite, zum Flansch des Tauchrohrs weisend
 - Seite S2: verschnittene, nicht konzentrische Flanscheite, zum Flansch des Stützens weisend
 - Gewindebohrungen f. Montage der Diagnostik nach Dok-Nr. 1-OSR-20000 Bl14.
 - Datenvorlage für Erstellung Passring:
 - as-built Modell Stützen AEM41 (E-Mail F. Herold vom 11.11.2013/ Vermessung von 11/2013)
 - Messprotokoll Tauchrohr CXRS am 07.01.2014 von J. Baldzuhn erhalten -> as-built Modell am 03.09.2014 von F. Herold
 - aktuelle Vermessungsdaten (Mitte Flansch + Vektor) von AS (E-Mail von T. Bräuer vom 09.05.2014 an H. Grevel)-> as-built Modell AEM41-FlanschAG am 12.05.14 von F. Herold
 - Forderung für Lage des Tauchrohres in as-built Position:
 1. nach Möglichkeit Tauchrohr in as-designed Position angeordnet.
 2. sollten größere Abweichungen/Verformungen vorliegen, sollte das Tauchrohr möglichst nahe der as-designed Lage angeordnet sein.
 3. der Mindestabstand (nach Verformung des PG inkl. Stützen Rohr2) soll in allen Lastfällen ≥ 10 mm betragen.
 - Nach Montage des Tauchrohres (mit Passring) sollen die Kontrollmaße im gekennzeichneten Bereich des Stützenrohres kontrolliert werden. Hierzu s.h. Kontrollskizze!

Hierzu igs-fle 1-qem41ba001--p-igs

Version: 1.1	Gezeichnet: 500	Überprüfen: S.A.
Änderungszust 2 Maßbohrungen hinzugefügt		
Bemessung: Schmitt B-B angepasst		
Version: 1.4.29	0.990, 76.55 dick	Mass: 35.210 kg
Datum: 05.02.2018	Vorkörper, Annelore	Norm: DIN ISO 2768-mK
Gezeichnet: 21.01.2019	Scholz, Peter	Form: FZ-1
Gezeichnet: 21.01.2019	Scholz, Peter	Form: A1
Datei: CATDRW-008238		
Max-Planck-Institut für Plasmaphysik, D-85748 Garching, D-7491 Greifswald		
Passring CF300 AEM41 + Anschluss Portliner Anschluss Portauskleidung Portauskleidung		
Rev: 000.000017	W7X	1/1
Proj. Leiter: S.A.	CA 991-21003	0000001